



GREATER VISAKHAPATNAM MUNICIPAL CORPORATION
FIRE PREVENTION WING

From,
The Commissioner,
Greater Visakhapatnam
Municipal Corporation
Visakhapatnam.

To,
The District Educational Officer,
Visakhapatnam District,
Visakhapatnam.

Rc.No.129/RFO/FPW/GVMC/2025, Dt. 14/05/2025

SUB: Greater Visakhapatnam Municipal Corporation – Fire Prevention Wing - Existing Building of **M/s.Pilani Public School under Shriram Siksha Samiti Pilani, Sy.No.480/2, AMTZ Campus, Nadupuru (V), Pedagantyada, Gajuwaka, Visakhapatnam – Fire No Objection Certificate for Occupancy - Issued - Reg.**

- REF:**
1. Letter Rc.No:5041/B2/97 of Director General, A.P Disaster Response & Fire Services Department, Dated: 12-03-2010.
 2. Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP. Sec/G1 Dt:13/09/2019.
 3. This office Provisional Fire No Objection Certificate issued vide Rc.No.73/RFO/FPW/GVMC/2025, Dt.22-03-2025.
 4. Application Dt.14-05-2025 of M/s.Pilani Public School under Shriram Siksha Samiti Pilani, Sy.No.480/2, AMTZ Campus, Nadupuru (V), Pedagantyada, Gajuwaka, Visakhapatnam for Fire No Objection Certificate for Occupancy.

It is to inform that, vide reference 3rd cited, Provisional Fire No Objection Certificate was issued to M/s.Pilani Public School under Shriram Siksha Samiti Pilani, Sy.No.480/2, AMTZ Campus, Nadupuru (V), Pedagantyada, Gajuwaka, Visakhapatnam

2. An application is received by this office for issuance of Fire No Objection Certificate for Occupancy to the same building which is ready to occupy.
3. Therefore, the Inspection Committee, Fire Prevention wing, GVMC inspected the premises of M/s.Pilani Public School under Shriram Siksha Samiti Pilani, Sy.No.480/2, AMTZ Campus, Nadupuru (V), Pedagantyada, Gajuwaka, Visakhapatnam on 14-05-2025 and submitted the following report.

3. Particulars of the building:

a)	Address of the Premises	M/s.Pilani Public School under Shriram Siksha Samiti Pilani, Sy.No.480/2, AMTZ Campus, Nadupuru (V), Pedagantyada, Gajuwaka, Visakhapatnam
b)	Total Plot Area	463.86 Sq.Mtrs.
c)	Height of the Building	04.26 Mtrs.
d)	No of blocks/ floors	02 Blocks / Ground floor
e)	Type of occupancy	Educational (School)

4. The floor wise details.

Sl. No.	Block	Floor	Area in Sq.Mtrs.	Type of Occupancy
1	Block-1	Ground	1444.47	Educational (School)
2	Block-2	Ground	1444.47	Educational (School)

5. The builder has proposed the following open spaces surrounding the building:

Side	Open spaces proposed by the builder in Meters
North (Front)	06.00
South	06.00
East	06.00

Handwritten signature and date: 14/05/2025

6. Details of Means of escape proposed in the Building

- The management proposed sufficient no. of doors to each building.

7. The details of Fire Fighting Equipment required and proposed by the builder as per Table-7, Part-IV of NBC-2016 for both blocks.

Sl. No.	Fire Safety Measures	Required	To be Provided	Deficit
1.	Fire Extinguishers as per IS 2190	28 Nos.	28 Nos.	Nil
2.	Hose Reel	04 Nos.	04 Nos.	Nil
3.	Terrace Tank	20,000 Ltrs.	20,000 Ltrs. (common to both blocks)	Nil
4.	Booster Pump	900 LPM	900 LPM common to both blocks)	Nil

8. The management has remitted an amount Rs.2889/- vide challan No.2025-CA-01230, Dt.14-05-2025 towards fire precautionary fees and penal interest.
9. The Fire safety systems were tested by the Inspection Committee, Fire Prevention Wing, GVMC during the inspection and performance found satisfactory and recommended for issuance of Fire No Objection Certificate for Occupancy.
10. Therefore, Fire No Objection Certificate for Occupancy is hereby issued to the Educational Building of M/s.Pilani Public School under Shriram Siksha Samiti Pilani, Sy.No.480/2, AMTZ Campus, Nadupuru (V), Pedagantyada, Gajuwaka, Visakhapatnam subject to the following conditions:

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached
iii.	All the occupants must know the correct method of operation of the fire fighting system installed
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All students / staff members of the institution shall be trained to operate the fire safety equipments during Emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

11. The Fire No Objection Certificate for Occupancy issued to M/s.Pilani Public School under Shriram Siksha Samiti Pilani, Sy.No.480/2, AMTZ Campus, Nadupuru (V), Pedagantyada, Gajuwaka, Visakhapatnam is valid for 01 (one) year from 14-05-2025 to 13-05-2026 and the Management shall submit the application for Renewal of Fire No Objection Certificate two (2) months before the date of expiry.
12. The issuing of Fire NOC is without any prejudice to the action taken by GVMC against Unauthorized Construction, if any made.

Y HANUMANTHA RAO, RFO(YHR)-RFO(TP)-GVMC, O/o REGIONAL FIRE OFFICER-TOWN PLANNING-GVMC

Regional Fire Officer

Digitally Signed by Y
Hanumantha Rao
Date: 14-05-2025 16:24:40
Reason: Approved

For Pilani Public School

Secretary

For Pilani Public School

Authorised Signatory